

Initial Notification of Applicability^b

National Emission Standards for Hazardous Air Pollutants:
Stationary Reciprocating Internal Combustion Engines

40 CFR Part 63 Subpart ZZZZ

☒ Yes, I am subject to 40 CFR Part 63 subpart ZZZZ National Emission Standards for
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines

NAICS code(s): 221119

Compliance Date: ☒ Existing source: May 3, 2013 ☐ New/reconstructed source: upon initial startup

Note: The May 3, 2013 compliance date for existing sources applies to the following engine types:

- Existing non-emergency compression ignition (CI) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions
- Existing stationary CI RICE located at an area source of HAP emissions

Company name: Industrial Power Generating Company, LLC.

Facility name (if different): Rockville

Facility (physical location) address: 2361 Lanier Road

Rockville, VA 23146

My facility is a (please choose one): ☐ Major source ☒ Area source

Owner name/title: Industrial Power Generating Company, LLC.

Owner/company address: 2250 Dabney Road
Richmond, VA 23030

Owner telephone number: 804-521-3500

RECEIVED
DEC 05 2012
3AP20

Owner email address (if available):

If the Operator information is different from the Owner, please provide the following:


Operator name/title:

Operator telephone number:

Operator email address (if available):

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine: 40 Detroit Diesel Series 60 Model 6063-GK60 Engines rated to 350 KW and 550 HP

I hereby certify that the information presented herein is correct to the best of my knowledge.


(Signature)

11/26/12
(Date)

Robert L. Greene, Environmental Compliance Manager
(Name/title)

(804) 521-3557
(Telephone No.)